

ND Dept of Health Water Quality NDPDES Wastewater Fact Sheet

Facility: Oakes City Of
 Permit Number: NDG120834
 Dept Contact: Permit Staff

Closest City: Oakes
 Minor

County: Dickey Pop: 1979
 General Permit Covered Facility POTW

Contacts

Oakes City Of		Owner-Operator	115 S 5th St Oakes ND 58474	
Pat Nelson	Public Works Supt	Contact	115 S 5th St Oakes ND 58474-1699	Office: 701.742.2137, Mobile: 701.710.0914
April Haring	City Auditor	Main Contact	115 S 5th St Oakes ND 58474-1699	Office: 701.742.2137

Permit Information

Number	Status	Start	End	Term Date
NDG120834	Reissue	10/1/2008	9/30/2013	

Inspections (Past 3 Years)

Inspection Date	Report	Inspector	Type	Joint Lead
7/30/2008	8/7/2008	Darin Billing	Waste Water	
6/18/2009	7/1/2009	Darin Billing	Waste Water	

Treatment Structures

Name	Type	Status	Inactive Date	Cell Size	Yr Built	Disc Pipe
Cell 1	Facultative Lagoon	Active		20.00	0	N
Cell 2	Facultative Lagoon	Active		12.90	0	N
Cell 3	Facultative Lagoon	Active		10.70	0	Y
Cell 4	Facultative Lagoon	Active		9.30	0	Y

Discharge Reviews (Past 3 Years)

	Sample Date	Status	Verbal Review	Reviewed By	Written Letter	BOD5	TSS	pH	Fecal	NH3
Cell 3	4/13/2010	Approved	4/20/2010	Curt Steier	4/26/2010	11	21	8.46		4.06
Cell 4	4/13/2010	Approved	4/20/2010	Curt Steier	4/26/2010	10	17	8.82		2.34
Cell 3	12/1/2009	Approved	12/9/2009	Curt Steier	12/14/2009	6	8	9.15*		0.5
Cell 4	12/1/2009	Approved	12/9/2009	Curt Steier	12/14/2009	6	6	9.18*		0.42
Cell 3	4/29/2009	Approved	4/29/2009	Curt Steier	5/12/2009	7	19	8.13		0.343
Cell 4	4/28/2009	Approved	4/29/2009	Curt Steier	5/12/2009	7	17	8.14		0.325
Cell 3	7/25/2007	Approved	7/31/2007	Marty Haroldson	8/7/2007	6	6	9.67*	10	0.17
Cell 4	7/31/2007	Approved	7/31/2007	Marty Haroldson	8/7/2007	6	5	9.65*	10	0.17

* indicates a potential exceedance based on the Facilities Permit limits.

DMRs Indicating Discharges (Past 3 Years)

ND Dept of Health Water Quality NDPDES Wastewater Fact Sheet

Discharge Pt	Start	End	Due	Received
001 A	12/10/2009	12/15/2009	4/30/2010	6/2/2010
001 A	12/10/2009	12/15/2009	4/30/2010	6/2/2010
001 A	5/1/2009	5/8/2009	10/31/2009	10/15/2009
001 A	5/1/2009	5/8/2009	10/31/2009	10/15/2009
001 A	7/31/2007	8/5/2007	2/29/2008	3/27/2008
001 A	7/31/2007	8/5/2007	2/29/2008	3/27/2008

Late or Overdue Permit Reports (Past 3 Years)

Disch Pt	Desc	Due Date	Recv Date	Days Late
001 A	DMR General - 001A-DMR Generated	8/31/2007	5/30/2008	273
001 A	DMR General 001A 08/01/2007-01/31/2008-DMR Generat	2/29/2008	3/27/2008	27
001 A	DMR General 001A 02/01/2008-07/31/2008-DMR Generat	8/31/2008	9/8/2008	8
001 A	DMR General 001A 10/01/2009-03/31/2010-DMR Generat	4/30/2010	6/2/2010	33

Activities/Events (Past 3 Years)

Type	Location	Start	End	Date Reported	Rpt Req	Rpt Rec'd
ByPass		4/25/2000	4/25/2000	4/27/2000	Y	5/2/2000
ByPass	Cell #1	7/23/2007	7/24/2007	7/25/2007	Y	7/25/2007
Notification	West Side Lift Station	3/30/2009	3/30/2009	3/30/2009	N	
ByPass	Flooding West Side Lift Station	4/21/2009	4/30/2009	4/22/2009	Y	1/13/2010
Notification	Flooding-Lagoon System	6/4/2009	6/4/2009	6/4/2009	N	
Notification	Flooding-Lagoons	3/24/2010	3/24/2010	3/24/2010	N	
Notification	Flooding-Lagoon System	4/8/2010	4/8/2010	4/8/2010	N	
Notification	Flooding Lagoons	4/23/2010	4/23/2010	4/23/2010	N	1/13/2010